

Summary of Facility Information in the County of Wibaux

Owner Name and Address: Wibaux County Shop PO Box 651 Wibaux MT 59353 Phone: (406) 795-2443

Sys Fac I	Location Name	Location Street Address	Location City	Zip	Location Phone
5502446	Wibaux County UST	2nd Ave N PO Box 86	Wibaux	59353	(406) 795-2443

TankID/Alt TankID Status	Tag Numbe	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	FR Met Spill/Overl/C
2 / 04 Currently in Use	2272	6/1/1995 11 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Bare Steel Cathodically Protected	Safe Suction	<div> <div>A B C D E F <input checked="" type="radio"/> H I J K L</div> <div>B D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes
3 / 05 Currently in Use	2273	6/1/1995 11 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Bare Steel Cathodically Protected	Safe Suction	<div> <div>A B C D E F <input checked="" type="radio"/> H I J K L</div> <div>B D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes
4 / 06 Currently in Use	2274	6/1/1995 11 / No	Used Oil 500	Polyethylene Tank Jacket Double-Walled	Bare Steel Cathodically Protected	Safe Suction	<div> <div><input checked="" type="radio"/> B C D E F <input checked="" type="radio"/> H I J K L</div> <div>B D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Summary of Facility Information in the County of Wibaux

Owner Name and Address: Wibaux Coop Oil Co PO Box 178 Wibaux MT 59353 Phone: (406) 795-2219

Sys Fac I	Location Name	Location Street Address	Location City	Zip	Location Phone
5503348	Wibaux Coop Oil Co	203 2nd Ave NW	Wibaux	59353	(406) 795-2219

TankID/Alt TankID Status	Tag Numbe	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	FR Met Spill/Overl/C
1 / 10 Currently in Use	2270	6/1/1995 11 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plastic None	Safe Suction	<div> <div>A B C D E F G H I J K L</div> <div>B D E F G H I J K L</div> </div>	Yes Yes Yes Yes
2 / 11 Currently in Use	2271	6/1/1995 11 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plastic None	Safe Suction	<div> <div>A B C D E F G H I J K L</div> <div>B D E F G H I J K L</div> </div>	Yes Yes Yes Yes
8 / 07 Currently in Use	2267	6/1/1995 11 / No	Gasoline 5,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plastic None	Safe Suction	<div> <div>A B C D E F G H I J K L</div> <div>B D E F G H I J K L</div> </div>	Yes Yes Yes Yes
9 / 08 Currently in Use	2268	6/1/1995 11 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plastic None	Safe Suction	<div> <div>A B C D E F G H I J K L</div> <div>B D E F G H I J K L</div> </div>	Yes Yes Yes Yes
10 / 09 Currently in Use	2269	6/1/1995 11 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plastic None	Safe Suction	<div> <div>A B C D E F G H I J K L</div> <div>B D E F G H I J K L</div> </div>	Yes Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Summary of Facility Information in the County of Wibaux

Owner Name and Address: Amsler C Store 102 2nd Ave N PO Box 16 Wibaux MT 59353 Phone: (406) 796-2338

Sys Fac I	Location Name	Location Street Address	Location City	Zip	Location Phone
5513559	Amsler C Store	102 2nd Ave N	Wibaux	59353	(406) 796-2338

TankID/Alt TankID Status	Tag Numbe	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	FR Met Spill/Overl/C
1 / 01 Currently in Use	3258	11/1/1994 11 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic Cathodically Protected	Safe Suction	<div> <div>A B C <input checked="" type="radio"/> E F G H I J K L</div> <div><input checked="" type="radio"/> D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes
2 / 02 Currently in Use	3259	1/1/1994 12 / No	Diesel 4,000	STI-P3 None	Flexible Plastic Cathodically Protected	Safe Suction	<div> <div>A B C <input checked="" type="radio"/> E F G H I J K L</div> <div><input checked="" type="radio"/> D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes
3 / 03 Currently in Use	3260	1/1/1994 12 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic Cathodically Protected	Safe Suction	<div> <div>A B C <input checked="" type="radio"/> E F G H I J K L</div> <div><input checked="" type="radio"/> D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes
4 / 04 Currently in Use	3261	1/1/1994 12 / No	Gasoline 4,000	STI-P3 None	Flexible Plastic Cathodically Protected	Pressurized	<div> <div>A B C <input checked="" type="radio"/> E F G H I J K L</div> <div><input checked="" type="radio"/> D E F G H I <input checked="" type="radio"/> K L</div> </div>	Yes Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed